NOTES FOR DESIGNER: (DO NOT INCLUDE ON CONSTRUCTION DRAWINGS) 1. WHEN EDITING DETAIL TO SUIT PROJECT, ADD JOB SPECIFIC REQUIREMENTS AND DELETE ONLY THOSE PORTIONS THAT DO NOT APPLY. TO SEEK A VARIANCE FROM APPLICABLE REQUIREMENTS, CONTACT THE ESM MECHNICAL POC. 2. SIZE PRV PER MANUFACTURER'S INSTRUCTIONS. 3. REFER TO THE FOLLOWING LANL STANDARDS FOR ADDITIONAL REQUIREMENTS: A. ENGINEERING STANDARDS MANUAL, MECHANICAL CHAPTER. B. SPEC 15140, POTABLE AND [NON-POTABLE] WATER PIPING. C. MECH DRAWING ST-D2020-1, SITE/BUILDING WATER COMPONENT DIAGRAM. 4. SUGGESTED PRV SETTINGS: A. BUILDING SERVICE; LEAD PRV NORMALLY SET AT APPROXIMATELY 55-60 PSIG WITH THE LAG PRV SET 3-5 PSIG LOWER. B. MISCELLANEOUS (TRAILERS AND TRANSPORTABLES): NORMALLY SET AT 40 PSIG. C. MAKE-UP WATER SYSTEMS (HEATING, COOLING, COOLING TOWERS, BOILERS, ETC.); NORMALLY SET AT 15-20 PSIG. 5. OTHER FILTERING DEVICES, (CENTRIFUGAL SEPARATORS, CARTRIDGE FILTERS, ETC.) MAY BE USED IN LIEU OF A STRAINER WHEN REQUIRED. DRAWING DEVELOPED FOR ML-3/ ML-4 PROJECTS. FOR ML-1/ ML-2, ADDITIONAL REQUIREMENTS AND QA REVIEWS ARE REQUIRED. (REMOVE THIS NOTE WHEN IN-SERTED INTO A DRAWING PACK-AGE). 2 8-14-02 DATE CLASS REV DESCRIPTION FACILITY & WASTE UPERATIONS
DESIGN ENGINEERING CONSTRUCTION SERVICES ENGINEERING STANDARDS MANUAL R.FROST WATER PRV PIPING DETAIL DESIGN NOTES DISCIPLINE POC: GURINDER GREWAL LOS Alamos
PO Box 1663
Los Alamos, New Mexico 87545 3 REVIEWER LARRY BAYS CHAPTER 6 ST-D2020-2 2